

- 12 -

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/NDZ/2023/ 894

Dated: 15/12/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Atal Adarash Bal Vidyalaya at Mandir Marg, New Delhi comprises of Ground + 01 Upper floor was earlier granted FSC by this department vide letter no. F6/DFS/MS/School/NDZ/2020/554 dated 16/12/2020. Now, The premises was re-inspected by the officer concerned of this department on 07/12/2023 in the presence of Sh. Suresh Chandra (Principal) and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and that the premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from 15/12/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 15/12/2023 at New Delhi by.

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal, Atal Adarash Bal Vidyalaya, Mandir Marg, New Delhi.
3. Sh. N.K.Gaur, Fire Officer, Fire Department, NDMC, Palika Kendra, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Basement if any shall be used as per NBC/BBL 1983.
6. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".